



KENTUCKY COMMUNITY AND TECHNICAL COLLEGE SYSTEM  
 COMMISSION ON FIRE PROTECTION PERSONNEL STANDARDS AND EDUCATION  
**FIREFIGHTER 1 COMPETENCY EVALUATION**



Objective(s): 5.3.18  
 2002 NFPA 1001 Standard



Primary Task: Shut off LP Gas

Candidate # \_\_\_\_\_

Skill No. **5-2** PERFORMANCE CRITERIA AND INSTRUCTIONS

INSTRUCTIONS TO THE MONITOR/EVALUATOR

1. Candidate shall be provided with an LP Gas tank (Propane) or a simulated LP Gas tank located at a structure.  
 (Tanks located at the evaluation site may be used in this objective)
2. The candidate shall be given the instructions below before beginning the exercise.

INSTRUCTIONS TO THE CANDIDATE

1. "The candidate, given an LP Gas (Propane) tank shall demonstrate procedures for shutting off the gas supply to the structure."

Minimum PPE: Full PPE except SCBA..

**PERFORMANCE**

YES NO

	YES	NO
➤ 1. Wears appropriate PPE.		
2. Locates the LPG tank.		
3. Finds the gas shut-off valve under the cover at the tank.		
4. Turns the valve in a clockwise direction to close.		

Reference: IFSTA Essentials 4th Edition, Chapter 14

TOTALS 

--	--

➤ **Critical Step-** Failure on this step mandates failure on task !

**CRITICAL TASK**

CANDIDATE MUST COMPLETE STEPS TOTAL TO PASS SKILL. 

<b>3</b>
----------

REMEMBER, YOU ARE AN EVALUATOR, NOT A TRAINER OF THE CANDIDATES DO NOT COACH, GRADE ONLY OBSERVED BEHAVIOR.

TEST DATE \_\_\_\_\_ LOCATION: \_\_\_\_\_

EVALUATOR NAME (Print): \_\_\_\_\_

EVALUATOR SIGNATURE: \_\_\_\_\_