



KENTUCKY COMMUNITY AND TECHNICAL COLLEGE SYSTEM
 COMMISSION ON FIRE PROTECTION PERSONNEL STANDARDS AND EDUCATION
FIREFIGHTER 1 COMPETENCY EVALUATION



Objective(s): 5.3.18
 2002 NFPA 1001 Standard



Primary Task: Shut off electric service

Candidate # _____

Skill No. 5-3 PERFORMANCE CRITERIA AND INSTRUCTIONS

INSTRUCTIONS TO THE MONITOR/EVALUATOR

- Candidate shall be provided with a structure with an electrical panel or a simulated electrical panel located at a structure.
 (Panels located at the evaluation site may be used in this objective)
- The candidate shall be given the instructions below before beginning the exercise.

INSTRUCTIONS TO THE CANDIDATE

1. "The candidate, given a facility with an electrical panel, shall demonstrate procedures for shutting off the electric supply to the structure."

Minimum PPE: Full PPE except SCBA.

PERFORMANCE

YES NO

1. Call the power company and have them disconnect the service.	<input type="checkbox"/>	<input type="checkbox"/>
2. If the power must be disconnected prior to the arrival of the power company, the firefighter may shut the power off at the electrical panel box.	<input type="checkbox"/>	<input type="checkbox"/>
➤ 3. Wear full protective equipment.	<input type="checkbox"/>	<input type="checkbox"/>
4. Locates the electrical panel box and/or main breaker.	<input type="checkbox"/>	<input type="checkbox"/>
5. Throws the main breaker or shut-off switch to the off position.	<input type="checkbox"/>	<input type="checkbox"/>

Reference: IFSTA Essentials 4th Edition, Chapter 14

TOTALS

➤ **Critical Step-** Failure on this step mandates failure on task !



CRITICAL TASK

CANDIDATE MUST COMPLETE STEPS TOTAL TO PASS SKILL.

4

REMEMBER, YOU ARE AN EVALUATOR, NOT A TRAINER OF THE CANDIDATES DO NOT COACH, GRADE ONLY OBSERVED BEHAVIOR.

TEST DATE _____ LOCATION: _____

EVALUATOR NAME (Print): _____

EVALUATOR SIGNATURE: _____